



Proposed Code Change  
State Form 41186R

RETURN TO:  
INDIANA DEPARTMENT OF HOMELAND SECURITY  
CODE SERVICES SECTION  
302 W. Washington Street Room W246  
Indianapolis, IN 46204

FOR OFFICE USE ONLY

Received 6/29/09

Code 50.8-09

INSTRUCTIONS:

Only TYPED copy accepted.

(KEY – Dashed line through material to be deleted, underline material to be added)

Use second sheet for any material requiring more space.

|  |   |                          |
|--|---|--------------------------|
| Code Title<br>2009 Indiana Residential Code  |   | Edition<br>First Edition |
| Section number and title<br>R502.11.4 Truss design drawings  |   | Page<br>1 of 1           |
| Proponent<br>Craig Wagner  | Title<br>Chief Building Inspector/ IABO Code Comm. Member |                          |
| Address<br>220 W Van Buren St, Columbia City IN 46725  |   | Phone<br>260-248-3111    |
| PROPOSED CODE CHANGE (Check One)   |   |                          |
| <input type="checkbox"/> Change to read as follows <input type="checkbox"/> Add to read as follows <input checked="" type="checkbox"/> Delete and substitute as follows <input type="checkbox"/> Delete without substitution   |   |                          |
| <p>Delete the first sentence of R502.11.4 and substitute as follows: <u>Truss design drawings shall be provided to the building official as required by, the General Administrative Rules (675 IAC 12) for Class 1 structures, or by local ordinance for Class 2 structures.</u></p> |   |                          |
| REASON AND FISCAL IMPACT   |   |                          |
| <p>Brings forward the amendment that clarifies requirements for truss drawings.</p> <p><b>Fiscal impact:</b> no increase to the cost of construction.</p>  |   |                          |
| REVIEW RECOMMENDATION  |   |                          |
| Approve  |   |                          |
| Disapprove   |   |                          |
| Approve as amended   |   |                          |
| Further Study  |   |                          |